



SGS Silver State Analytical Laboratories
3626 E. Sunset Road, Suite 100
Las Vegas, NV 89120
(702) 873-4478
www.ssalabs.com

June 11, 2024

Leroy Daines
Utility Services
PO Box 35908
Las Vegas, NV 89133

Lab ID:
Las Vegas, NV (NV930, CA3029)

Project: Hillcrest Manor NV0145

Workorder No.: 24060436

Dear Leroy Daines:

SGS Silver State Analytical Laboratories received 1 sample(s) on 6/10/2024 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted below. Analytical results reported as non-detect (ND) in the result field are below the Practical Quantification Limit (PQL). Analytical results above the PQL are reported as the measured value in the results field.

Quality control data is within laboratory defined or method specified acceptance limits except if noted.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads "Michael Mitchell".

Michael Mitchell
Laboratory Director
3626 E. Sunset Road, Suite 100
Las Vegas, NV 89120

ssalabs.com

Original



SGS Silver State Analytical Laboratories
 3626 E. Sunset Road, Suite 100
 Las Vegas, NV 89120
 (702) 873-4478
 www.ssalabs.com

Analytical Report

WO#: 24060436
 Date Reported: 6/11/2024

CLIENT: Utility Services **Collection Date:** 6/10/2024 12:40:00 PM
Project: Hillcrest Manor NV0145
Lab ID: 24060436-01 **Matrix:** DRINKING WATER
Client Sample ID 5750 Sheila - Hose Bibb

Analyses	Result	RL	Qual	Units	MCL	DF	Date Analyzed
COLIFORMS - P/A (DRINKING WATER)				COLILERT-18		Analyst: JJF	
Coliform, Total	Absent			P/A	1		6/10/2024 4:40:00 PM
Escherichia Coli	Absent			P/A	1		6/10/2024 4:40:00 PM

Qualifiers:
(Qual)

DF Dilution Factor.
 MCL Maximum Contaminant Level.
 PQL Practical Quantitation Limit.

H Holding times for preparation or analysis exceeded.
 ND Not Detected at the PQL.

Original

